ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Product Service

CERTIFICATE

No. B 058309 0005 Rev. 00

Holder of Certificate: **GEZE GmbH**
Reinhold-Vöster-Str. 21-29
71229 Leonberg
GERMANY

Production Facility(ies): 058309

Certification Mark:

Product: **Power supply equipment (for smoke + heat extraction Emergency Power Control)**

Model(s): **THZ, THZ Comfort**

Parameters:

rated voltage:	230 V AC
rated frequency:	50 Hz
rated power:	100 W
output voltage:	24 V DC
output current:	3,4 A
duty cycle:	30 %
protection class:	I
protection degree:	IP 30

Tested according to: EN 60335-1:2012/A13:2017

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 028-713128626-000
Valid until: 2024-02-10

Date, 2019-02-20 (Abdul Sabbagh)

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

A4 / 07.17